

FIRE SAFETY CERTIFICATE

No. 84

Dated: 12/2/24
APPENDIX - XII

Certified that the S.A. Mission English Medium High School, Nandurbar (name of the building or premises) at

Babagaribdas Nagar, Parshuram Chowk, Nandurbar-425412 (address) comprised of Two Separate buildings, having 1 Ground floor + 2 upper floor (1st Floor +2nd Floor)

basement(s)) owned/ occupied by The Suvarta Alliance Ministries Trust, Nandurbar

(name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 12/2/24 (date of inspection) in the presence of

Dr. Sunita S. Ahire , Principal, S.A. Mission English Medium High School, Nandurbar (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes X(tenth) (~~XI-XII~~) With effect from

12/02/2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended: -

In Compliance with **Maharashtra Fire Prevention & Life Safety Measures Rules, 2009** ;

1. Placing fire fighting equipment and fire extinguishers hydrate system foam in office or hall
2. Keeping access open on both sides
3. 24 hours is sufficient to build a cistern or sit in a Sithtex tank so that water is available quickly
4. Keeping buckets filled with fire retardant balu for emergency situations
5. Placing appropriate warning signs for exits as a precaution
6. Flammable materials should not be kept in the office or building.
7. Keep the width of the road in accordance with the Fire extinguisher Vehicle so that During emergence time Fire extinguisher Vehicle should passed smoothly (access & approach)
8. Fire doors near stairways in floor passageways should be closed.
9. Do not use electrical equipment carelessly
10. A single electrical outlet should be used on the electrical plug.
11. Cabinet documents, cupboards, racks etc. should not be attached to electrical switch boards
12. When leaving the office or home, switch off the lights and air conditioners.
13. No smoking in the building
14. Construction of water cistern on each floor of multi-storied building and emergency situation
A pipeline should be laid up to the first floor for quick water supply through the fire service.
It will be our soie responsibility to do so. This responsibility belongs to the Institution.


Executive Director
Suvarta Alliance Ministries Trust
Nandurbar




HEAD MISTRESS
A.M. English Medium High School
Nandurbar (Nandurbar)

15. Your organization will be fully responsible for fire damage.


16. Fire audit by the fire agency appointed by the government should be conducted and certificate should be produce to The Municipal Council.

17. The certificate issued shall remain valid for a period of one year from the date of issue

The certificate is being issued subject to the above conditions.

Issued on ...12/02/2024.... (date of issue) at Nandurbar... (place) by

*Strike out whichever is not applicable.

Signature with Seal: 

Name : Anand B. Mane

Designation : Assist. Fire Officer

Name & Address of Department/ Office: Nandurbar Municipal Council,
सहायक अग्निशमन अधिकारी
नंदुरबार नगर परिषद



To

S.A. Mission English Medium High

School, Nandurbar

Babaqaribdas Nagar, Parshuram

Chowk, Nandurbar-425412

(Name & Address of the Institution)


ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


 Executive Director
 Suvarta Alliance Ministries Trust
 Nandurbar


 HEAD MISTRESS
 A.M.English Medium High School
 Nandurbar (Nandurbar)

